

SQAD-6 Quality Control Notice (QCN)

Sub Code: PUMP

FME IN RECIRC PUMP SEALS

The vendor shall verify that there are no foreign materials in the breakdown coils and any ports. Certification shall state that the vendor has inspected the breakdown coils and any ports, as applicable, for foreign material prior to shipping new seal cartridge assemblies for BWR Reactor Recirculation Pump Seals.